



Evaluation Report CCMC 13581-R Ag-Tuf®

MasterFormat:	09 72 10
Evaluation issued:	2012-02-23
Re-evaluated:	2018-06-21

1. Opinion

It is the opinion of the Canadian Construction Materials Centre (CCMC) that “Ag-Tuf®,” when used as a polyvinyl chloride (PVC) wall liner in agricultural buildings in accordance with the conditions and limitations stated in Section 3 of this Report, complies with the National Farm Building Code of Canada 1995:

- Article 3.1.5.1., Fire Resistance Ratings

This opinion is based on CCMC’s evaluation of the technical evidence in Section 4 provided by the Report Holder.

2. Description

The product is a corrugated PVC panel that is intended for use as an interior wall liner in agricultural buildings. The profile thickness is 20 gauge (0.81 mm).

3. Conditions and Limitations

CCMC’s compliance opinion in Section 1 is bound by the “Ag-Tuf®” being used in accordance with the conditions and limitations set out below.

- The PVC corrugated panel is intended to be used as a wall liner on the interior of agricultural buildings.
- The product is not intended to be used as a cladding.
- The installer must follow the manufacturer’s installation instructions and the guidelines for the spacing of fasteners.
- The product must be identified with the phrase “CCMC 13581-R”.

4. Technical Evidence

The Report Holder has submitted technical documentation for CCMC’s evaluation. Testing was conducted at laboratories recognized by CCMC. The corresponding technical evidence for this product is summarized below.

4.1 Material Requirements

Table 4.1.1 Results of Testing of Material Requirements of the Product

Property	Requirement	Result
Flame-spread rating	Report Value	0
Smoke development	Report Value	70
Chemical resistance	Report Value	No sign of any change

Report Holder

Palram Americas, Inc.
Arcadia West Industrial Park
9735 Commerce Circle
Kutztown, PA 19530
USA

Telephone: 610-285-9918

Fax: 610-285-9928

Email: sales@palram.com

Web: www.palramamericas.com

Plant(s)

Kutztown, PA, USA

Disclaimer

This Report is issued by the Canadian Construction Materials Centre, a program of NRC Construction at the National Research Council of Canada. The Report must be read in the context of the entire CCMC Registry of Product Evaluations, including, without limitation, the introduction therein which sets out important information concerning the interpretation and use of CCMC Evaluation Reports.

Readers must confirm that the Report is current and has not been withdrawn or superseded by a later issue. Please refer to http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html, or contact the Canadian Construction Materials Centre, NRC Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone 613-993-6189. Fax 613-952-0268.

NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Report are directed to those who have the appropriate degree of experience to use and apply its contents. This Report is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Report. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.

Date modified:

2018-06-26